

# FIRE PREVENTION GUIDELINES

1. Fire hydrants shall be clear of obstructions within a radius of ten feet.
2. There shall be a 20-foot wide fire access from the fire lane to the fire hydrant.
3. Fire call boxes shall be clear of obstructions within a 5-foot radius.
4. No vending carts, stands, stages or any other structure or equipment shall be constructed or placed within five feet of a cross or connecting street or alley.
5. No vending carts, stands stages or any other structure or equipment shall in any way obstruct or impede the egress from any building.
6. A 20-foot fire lane shall be maintained throughout the entire area that is used for the festival. The centerline of the fire lane shall run exactly with the centerline of the street.
7. A copy of the site drawing shall be submitted to, and approved by the Fire Marshal. **(THIS IS NOT APPLICABLE - Applies to DCCC).**
8. Vendors using hazardous materials for cooking shall get special approval from the Fire Marshal.
  - a. Drawings are to be submitted to the Fire Prevention Division noting the location of vendors, type of cooking fuel, type of fire extinguishers (minimum 2A-10BC), name, address, and telephone number of the owner of the vending operation.
  - b. A copy of the approved drawings shall be with the vendor at all times.
9. The use of propane shall be limited to (1) One 20 pound bottle per appliance unless otherwise approved by the Fire Marshal.
10. Changing of propane bottles while the festival is open to the public is prohibited.
11. Gasoline powered generators shall have a built-in tank with a maximum tank capacity of three gallons.
12. Refueling of gasoline-powered generators while the festival is open to the public is **strictly** prohibited.
13. Storage of additional gasoline on site is **strictly** prohibited.
14. There shall be a 10-foot wide fire access for every 25 feet of vending space.